

## FIRE SAFETY CERTIFICATE

No.Sfo/KNR/2023

Dated:21/11/2023

Certified that the PARAMITA WORLD SCHOOL at Alugunoor, Karimnagar Dist. Telangana state comprised of one basement and G+3 (upper floors) owned/ occupied by PARAMITA WORLD SCHOOL have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 21/11/23 (date of inspection) in the presence of Mr.Vindod Rao (name and addresses of the Manager/ Secretary or his representative) and that the building/premises is fit for occupancy upto classes I TO X With effect from 2023-24 for a period of three year in accordance with rule and subject to compliance of specific conditions as appended:-

1. Regular checking of firefighting equipment
- 2.
- 3.
- 4.

Issued on .. 21/11/2023 (date of issue) at Karimnagar (place) by

\*Strike out whichever is not applicable.

Signature with Seal: .....  
 Name T. Parameshwaram  
 Designation JCA  
 Name & Address of Department/ Office: Fire Department

STATION FIRE OFFICER  
 FIRE STATION, KARIMNAGAR

To

The Principal  
 PARAMITA WORLD SCHOOL,  
 Alugunoor Karimnagar.  
 (Name & Address of the Institution)

## ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

M.S. Kar  
 Principal  
 PARAMITA World School  
 Affiliated to the CBSE # 3630442  
 Alugunoor, Karimnagar.




SECRETARY & CORRESPONDENT  
 BALMURI AND ENUGANTI EDUCATIONAL SOCIETY,  
 KARIMNAGAR.





GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT



From  
The District fire officer,  
Karimnagar Division.

To,  
E.PRASAD RAO,  
alugunoor(Vill),  
thimmapur(Mndl),

Ack. No.389520002021 Dated:31/07/2021



Sir,

Sub: TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –Karimnagar Division. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of IRIS WORLD SCHOOL,alugunoor(Vill),thimmapur(Mndl)/- Alugunur/Timmapur (LMD Colony)/Karimnagar , – Regarding.

Ref: 1. Acknowledgement No 389520002021  
2. This Office NOC for Occupancy Ack/RC No.449/RFO/CR-II/2014 dt.31/07/2021  
3. Non Multi storeyed Building Inspection Committee Report, Ack. No. 389520002021, dt. 31/07/2021

\*\*\*\*\*

- 1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of IRIS WORLD SCHOOL,alugunoor(Vill),thimmapur(Mndl)/-Alugunur/Timmapur (LMD Colony)/Karimnagar
- 2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with 1 Ground, 3 Floors, with a height of 14.00 Meters for EDUCATIONAL B-1 Schools up to senior secondary level Occupancy .
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with 1 Ground, 3 Floors, with a height of 14.00 Meters for EDUCATIONAL B-1 Schools up to senior secondary level Occupancy
- 4) Open Spaces:The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
a 1	North	6.00	6.00
2	South	6.00	6.00
3	East	6.00	6.00
4	West	6.00	6.00
b Sl.No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
1	Entry gate width	6.00	6.0
2	Entry Gate Head Clearance	6.00	6.0
3	Exit Gate Width	6.00	6.0
4	Exit Gate Head Clearance	6.00	6.00

5) Travel Distance


Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point ( Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	15.00	15.00
2	The Dead end of the corridor length in exit access. ( 6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	6.00

6) Stair Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to

M. Sankar  
Principal

PARAMITA World School  
Affiliated to the CBSE # 3630442  
Alugunoor, Karimnagar.



SECRETARY & CORRESPONDENT  
BALMURI AND ENUGANTI EDUCATIONAL SOCIETY,



1	Internal staircases	1.75	1	Ground	Terrace
2	External staircases	1.75	1	Ground	Terrace

7) Means of Escape Floor Wise Details :

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Ground	860.05	EDUCATIONAL B-1 Schools up to senior secondary level	215.00	4.30	10.00
2	1st Floor	860.05	EDUCATIONAL B-1 Schools up to senior secondary level	215.00	4.30	8.00
3	2nd Floor	860.05	EDUCATIONAL B-1 Schools up to senior secondary level	215.00	4.30	8.00
4	3rd Floor	860.05	EDUCATIONAL B-1 Schools up to senior secondary level	215.00	4.30	8.00

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automatic detection and alarm system
1	Ground	5.00	1.00	0.00	0.00	0.00
2	1st Floor	5.00	1.00	0.00	0.00	0.00
3	2nd Floor	5.00	1.00	0.00	0.00	0.00
4	3rd Floor	5.00	1.00	0.00	0.00	0.00

10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	32	32
First Aid Hose Reel	8	8
Down Comer	2	2
Manually Operated Electronic Fire Alarm Systems	8	8
Terrace Tank over Respective Tower Terrace in Litres	25000	25000
Pump Capacity in LPM at the Terrace Tank Level with Minimum Pressure of 3.5 kg/cm <sup>2</sup>	900	900

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there is no deficiencies.

12. Remarks :

As per the recommendation of Sfo Karimnagar and Adfo Gajwel (FAC) of Adfo Karimnagar Division, it is approved for issue of Renewal of Occupancy NOC.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **IRIS WORLD SCHOOL,alugunoor(Vill),thimmapur(Mndl)/-Alugunur/Timmapur (LMD Colony)/Karimnagar** with a height of **14.00** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection	All the escape/exit roots shall	All the occupants must know the correct

	arrangements shall be maintained in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	not be kept locked/blocked or encroached	method of operation of the fire fighting systems installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,  
District fire officer,  
Karimnagar Division.

Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"

*M. S. K. K.*  
**Principal**  
**PARAMITA World School**  
Affiliated to the CBSE # 3630442  
Alugunoor, Karimnagar.



*R. K. K.*  
**SECRETARY & CORRESPONDENT**  
**BALMURI AND ENUGANTI EDUCATIONAL SOCIETY,**  
**KARIMNAGAR.**